



- 1 CJC fine filter with water separation and transfer pump. 700 litres/hour.
- 2 Storage tank. 120 m³
- 3 Day tank. 3 m³
- 3.1 Alarm with pump start/stop
- 3.2 Cover with cock arrangement
- 4 Engine connection system
- 4.1 Flow metre
- 4.2 Engine filter
- 4.3 Mix tank. 8 litres
- 4.4 Air cooler
- 5 Tray for engine connection
- 5.1 Tray for day tank
- 5.2 Tray for storage tank

Capacity

W/D Generator sets
Standby
Wind turbines
Freshwater

2 x 740 = 1480 kW
1 x 740 = 740 kW
2 x 850 = 1700 kW
up to 20 m³/day

Drw. Fuel system - principle
Customer Name

VESTESSEN A/S
Gunnar Clausens Vej 11, 1
DK-8260 Viby J
Tel +45 86 30 06 01



No 011-0-0000
Project Number - Place 25 September 2006

Fuel system